TRANE
E
NOMENCLATURE

A-1 COMPRESSOR

2 E 5 J 4 8 R L X

UNLOADERS
T= 1/2, 2/3, 100% UNLOADING
W= 100% UNL, ACTUATOR ON STD # OF CLY
X= NO UNLOADERS OR ACTUATOR
Y= 100% UNLOADERS, NO ACTUATOR
Z= STD. NO. OF CYL. UNL., NO ACTUATOR
N= SOLENOID UNLOADING
P= PARALLEL UNITS
U= 50% UNLOADING WITH ACTUATOR
NO LETTER= STD NO. OF CYL. W/ACTUATOR

VALVES
NO LETTER= STD. LIFT VALVES
L= LOW LIFT VALVES

RH OR LH
NO LETTER = LEFT HAND OR STD. UNIT
L= RIGHT HAND UNIT

ELECTRICAL CHARACTERISTICS

1= 460/60/3 (6 LEADS)	5= 575/60/3
3= 200/230/60/3	8= 200-230/460/60/3
4= 460/60/3 (3 LEADS)	

DISPLACEMENT AND NUMBER OF CYLINDERS (CU. IN.)

4= 115.5	6= 173.3
5= 144.5	8= 231.0

DESIGN SEQUENCE

MOTOR SPEED
5= 1800 RPM
3= 3600 RPM
7= MULTI-SPEED

BORE 3.660

REFRIGERANT TYPE 1 = R-12 2 = R-22